

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #: PRRES20171556

Address: 1721 NE PARKWOOD DR, LEES SUMMIT, MO 64064

Inspected On: Tuesday, November 21, 2017

Inspected By: Khanh Nguyen

12/21/2017 12:00:00 AM **Expiration Date:**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection -Khanh Nguyen Temporary C of O

Tuesday, November

Codes Residential 21, 2017

Corrective Action Required:

Misc -INSTALL ROOF DRAINAGE SYSTEM 1

-RECEPTACLE IN MASTER TOILET NOT GFCI-PROTECTED

-GAARGE DOOR NOT SELF-CLOSING

-COMPLETE KITCHEN PLUMBING AND APPLIANCE

-COMPLETE PLUMBING IN BASEMENT: WATER HEATER; PRESSURTE

REDUCER, SECURE PEX

-INSTALL ANTI-BACKFLOW AT BASEMENT HOSE BIBB