

CODES ADMINISTRATION

Residential Plan Review

November 22, 2017

D AND D BUILDING INC PO BOX 7014 LEES SUMMIT, MO 64064 (816) 491-2125

Permit No: PRRES20173808
Plan Name: 4716 NE POCONO CR

Project Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064

Parcel Number: 43100035100000000

Location: MONTICELLO 2ND PLAT LOTS 33-67 & TRACTS D-F---LOT 37

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - FINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Troy Thompson Pending

Residential Plan Review Reviewed By: Kim Brennan Rejected

- 1. Identify roof covering material (IRC Section R905)
- 2. Footings, column pads, piers and grade beams reinforcement size and spacing. no reinforcement size and spacing for column pads in the garage.
- 3. Identify braced wall locations and length of braced wall panel(s). (IRC Section R602.10)
- 4. Provide details for any walls over 10 feet in height. Include stud grade, size, spacing and actual, uninterrupted height. (IRC Section 602.3.1 and Table 602.3(5) & 602.3.1)
- 5. Identify interior load bearing walls. (IRC Section R602) unable to follow the load path

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	

Residential, Living Area Residential, Un-Finished basements Residential, Finished basements Residential, Decks Residential, garage		1919				
		392 1380 280				
					771	
					Residential, Living Area 2	
Roofing Material		Number of Bathrooms	4.5			
Number of Bedrooms	5	Number of Stories	2			
Number of Living Units	1	Total Living Area	4697			
Sewer Connection Fee	20					