

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial
LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Fire Line - Flush	Matt Munger	Passed	Monday, November 27, 2017

Informational

- 1 Matt Munger 11/27/2017 9:15 AM
Line was chlorinated and de-chlorinated prior to this flush but Kevin had vehicle issues so we are flushing the line again and letting it sit for 24 hours, then we will return to take samples on Tuesday the 28th.

Comments: