

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173421, Building Permit - Residential

Address: 612 NW OLIVE ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Not Ready	Monday, November 27, 2017

Corrective Action Required

1	Misc	VERTICAL RE-BAR DRIVEN INTO TRENCH BOTTOM
---	------	---

Footing Inspection - Residential	John Borns	Failed	Monday, November 27, 2017
--	-----------------------	-------------------	--------------------------------------

Corrective Action Required

1	Misc	VERTICAL RE-BAR DRIVEN INTO TRENCH BOTTOM
--------------	-----------------	--

Footing Inspection - Residential	John Borns	Passed	Monday, November 27, 2017
---	------------	--------	---------------------------

**Comments: OK TO POUR WHEN READY TRENCH FOOTING FOR PERIMETER WALL.
REQUEST INSPECTION OF ISOLATED PIERS WHEN READY.**