

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential  
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| <b>Inspection:</b>                  | <b>Inspector:</b> | <b>Outcome:</b> | <b>Date:</b>                     |
|-------------------------------------|-------------------|-----------------|----------------------------------|
| DEI-Miscellaneous PWORKS Inspection | Brice Lawson      | Passed          | Tuesday,<br>November<br>28, 2017 |

Informational

- 1 Brice Lawson 11/28/2017 3:04 PM  
Bryan Byrd witnessed the tracer wire testing for the laterals for lots 72 thru 76 and lot 96 on sanitary line A. The tracer wires on the laterals that tie-in to the sanitary main lines B,C,D and E have been tested. These tracer wires were locatable with the equipment used by Redford Construction.

Comments: