

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, November 29, 2017

Partial Correction

1 Misc

OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT CEILING AND WALLS AT:

LINK CORRIDOR A111 SOUTH 36' + "B"-TO-COMMONS LINK;  
CORR 205 WALLS + LID; CORR A-305 LID & WALLS; CORR 405;  
CORR 219; CORR 207; LOBBY 205; CORR 219; LOBBY 224; LOBBY 309; CORR 305 S; CORR 307; CORR 319; CORR 405; CORR 419;  
CORR 407; LOBBY 409; ELEV LOBBY 324 1ST LAYER; LOBBY 424 EXCEPT CHASE; 524 INCL "ATTIC" LEVEL; CORR 507; CORR 519; LOBBY 509; 224 SE & SW CORNERS ONE LAYER; 324 CHASES AT SE & SW CORNERS 1ST LAYER; 424 CHASES AT SE & SW CORNERS 1ST LAYER; 424 CHASES AT SE & SW CORNERS 1ST LAYER; **[2ND LAYER 5/8" TYPE X AT TWO INNER WALLS AT SE & SW CORNER CHASES AT 524, 424, 324, 424;**

UNITS/ROOMS: 201; 203; 204; 206; 209; 210; 212; 213 CHASE 1ST LAYER; 213 CHASE 2ND LAYER AT REAR WALL; 217; 218; 221; 222; 225; 226; 227; 228; 229; 231; 232; 233; 234;

UNITS/ROOMS: 301; 303; 304; 306; 308; 310; 312; 313 EXCLUDING CHASE; 313 CHASE 1ST LAYER; 313 CHASE 2ND LAYER AT REAR WALL; 321; 322; 325; 326; 328; 332; 333; 334; 314; 315 EXCLUDING CHASE; 316; 317/318; 327; 329; 331;

UNITS/ROOMS: 401; 403; 404; 406; 408; 410; 412; 413 1ST LAYER; 413 CHASE 2ND LAYER AT REAR WALL; 415; 416; 417/418; 421;

422; 425; 426; 427; 428; 429; 431; 432; 433; 434;

UNITS/ROOMS: 506; 508 INCL "ATTIC" LEVEL; 510; 512; CHASE AT 513 1ST LAYER; 513 INCL 2ND LAYER AT CHASE; 513 CHASE 2ND LAYER AT REAR WALL; 514; 515; 516; 517/518; 521; 522 ABOVE CEILING AT S WALL; 522; 525 ; 526; 527; 528;

Partial Correction

2

Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLIES AT STAIRWELLS:

STAIR 103/202/302/402: FRAMING & ENCLOSED SYSTEMS AT WELL FACE EXCEPT AT ATTIC ACCESS;

ABOVE CEILING AT BACKSIDE OF STAIRWELL WALL AT: 201; 222; 301; 322; 206; 401; 405/431; 406; 408; 422;

**ONE LAYER 5/8" TYPE X AT WELL FACE AT STAIRWELLS: [#1; #2; #3 PARTIAL;**

**Comments:**