

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20173752, Building Permit - Residential

Address: 1713 SW NAPA VALLEY DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Dale Carter	Failed	Wednesday, November 29, 2017

### Corrective Action Required

- |   |      |   |
|---|------|---|
| 1 | Misc | 1. Firestop along tops of furred-out walls, at ends / along furred-down ceiling, at edge of stair landing, and vertically along furred-walls every 10'.<br>2. BOCA plate at top of 3" DWV, where it enters into joist space.<br>3. Extend water heater pressure relief discharge pipe.<br>4. If area under front porch is to be separated by a door, will need to provide a GFI-protected outlet inside the room. |
|---|------|---|

### Comments: