

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20162334  
**Address:** 1316 NE BRANDYWINE RD, LEES SUMMIT, MO 64064  
**Inspected On:** Thursday, November 30, 2017  
**Inspected By:** Khanh Nguyen  
**Expiration Date:** 12/29/2017 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Temporary C of O	Thursday, November 30, 2017

**Corrective Action Required:**

- |   |      |  |
|---|------|--|
| 1 | Misc | -INSTALL AN INTERBONDING TERMINAL BLOCK NEAR SERVICE METER   |
|   |      | -INSTALL OVEN AND WATER HEATER BREAKER LOCKS   |
|   |      | **THE DEVICES MUST NOT ONLY BE ABLE TO LOCK THE BREAKER IN THE OPEN POSITION, IT ALSO MUST ALLOW THE BREAKER TO TRIP |
|   |      | -WHERE IS THE USER GROUNDING CONNECTION?   |
|   |      | **THE GROUNDING CONNECTION MUST BE ACCESSIBLE  |