

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173752, Building Permit - Residential

Address: 1713 SW NAPA VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Dale Carter	Failed	Thursday, November 30, 2017

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | 1. Firestop along tops of furred-out walls, at ends / along furred-down ceiling, *still need at corner where furred-out wall meets stair, and at top of steel post by stair*
--, and vertically along furred-walls every 10'. *boards have been put in place, but at greater than every 10', and only one of these has been foamed.* |
| | | 3. Extend water heater pressure relief discharge pipe. |

Comments: