

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162403, Building Permit - Commercial

Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Thursday, November 30, 2017

Corrective Action Required

1	Misc	ELECT RECEPT AT PANEL MUST BE GFCI PROTECTED
2	Misc	ELECT RECEPT AT BREAK VANITY MUST BE GFCI
3	Misc	LABEL ALL BREAKERS AT PANEL
4	Misc	WATER CLOSET SEAT NOT COMMERCIAL OPEN FRONT TYPE
5	Misc	RESTROOM SINK HIGHER THAN 34" MAXIMUM HEIGHT
6	Misc	RESOLVE FIRE DEPT ISSUES
7	Misc	RESOLVE CIVIL SITE ISSUES
8	Misc	RESOLVE PLANNING ISSUES

Occupancy Inspection - Fire	Michael Weissenbach	Issues provided	Thursday, November 30, 2017
------------------------------------	---------------------	-----------------	-----------------------------

Comments: