

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161926, Building Permit - Commercial

Address: 783 NW DONOVAN RD, Unit:C1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	John Borns	Partial	Friday, December 01, 2017

Partial Correction

1 Misc

**OK TO POUR WHEN READY POST PIERS: FAR NORTH ONE
INSPECTED/APPROVED. OTHER FOUR POURED WITHOUT
INSPECTION.**

Piers/Caissons Inspection - Commercial	John Borns	Not Ready	Friday, December 01, 2017
---	------------	-----------	---------------------------

Comments: