Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173638, Building Permit - Commercial Address: 615 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - John Borns Partial Friday, December 01, 2017

Commercial

Partial Correction

1 Misc OK TO COVER WALLS AT: CLERICAL STAFF AREA EXCEPT AT

LOCATIONS WHERE HOLES IN TOP AND BOTTOM PLATES MUST

BE FIRE-BLOCKED;

Comments: