

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20173752, Building Permit - Residential

Address: 1713 SW NAPA VALLEY DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Dale Carter	Failed	Friday, December 01, 2017

### Corrective Action Required

1	Misc	1. Firestop along tops of furred-out walls, at ends / along furred-down ceiling, *still need at corner where furred-out wall meets stair, and at top of steel post by stair* --, and vertically along furred-walls every 10'. *boards have been put in place, but at greater than every 10', and only one of these has been foamed.*
---	------	---

\*\*Boards are now every 10', but only a few have now been foamed. Still need to address the two locations near the stair.

### Comments: