

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171395, Building Permit - Commercial

Address: 110 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Friday, December 01, 2017

Corrective Action Required

1 Misc

NO PERMIT PRINTS ON SITE

Corrective Action Required

2 Misc

NOT READY FOR INSPECTION. REPLACE BOTTOM PLATE WITH TREATED LUMBER. THEN REQUEST IN-WALL INSPECTION.

CONTACT INSPECTOR FOR OTHER SPECIFIC ISSUES.

Comments: