

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171326, Building Permit - Residential

Address: 1828 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Dale Carter	Failed	Friday, December 01, 2017

Corrective Action Required

1	Misc	1. Obtain sprinkler permit. 2. Extend sump discharge away from foundation. 3. A ground-prong is broken off in the outlet in the garage. 4. Patch holes in garage wall. 5. Secure electric receptacle yokes - throughout. 6. Electric receptacle is not permitted above the bathtub - master bath.
---	------	--

Plot Plan Inspection	Dale Carter	Passed	Friday, December 01, 2017
-----------------------------	-------------	--------	---------------------------

All Rough Inspection - Residential	Mike Copeland	Passed	Friday, December 01, 2017
---	---------------	--------	---------------------------

Erosion Control	Dale Carter	Passed	Friday, December 01, 2017
------------------------	-------------	--------	---------------------------

Comments: