



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20171355	Date:	December 04, 2017
Project Title:	CONTROL SERVICE COMPANY	Applicant:	
Location:	3621 NE AKIN DR, LEES SUMMIT, MO 64064		ADVANTAGE FIRE PROTECTION SYSTEMS INC 404 B NW 11TH ST BLUE SPRINGS, MO 64015
Type of Work:			
Occupancy Group:			
Description:	TENANT FINISH FOR OFFICE WITH SOME STORAGE	Primary:	(816) 224-3400

**due to timing both this TF permit and the shell were approved simultaneously. This permit will be voided and all fees and any relevant plan review conditions will be moved to full building permit PRCOM20170784

Construction Type: Not Applicable
Map Page: 175M

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Field tests and acceptance testing will be required prior to the final occupancy inspection.
Contact the fire department to schedule testing. 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.