

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171410, Building Permit - Commercial

Address: 1621 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Passed	Monday, December 04, 2017
Gas Piping Inspection - Commercial	John Borns	Passed	Monday, December 04, 2017

Comments: GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >=10 MIN. VISUAL INSPECTION OK. RELEASE GAS SERVICE.