

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20171140, Building Permit - Residential

Address: 1522 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Dale Carter	Failed	Tuesday, December 05, 2017

### Corrective Action Required

1	Misc	Pier holes to extend 3' below grade to undisturbed soil.
---	------	--

### Comments: