

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173814, Building Permit - Residential

Address: 206 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Partial	Tuesday, December 05, 2017

Partial Correction

1	Misc	COMPLETE FIRE-BLOCKING OF TOPS OF PLUMBING CHASES AT 2ND FLR BA S WALL; ALSO TOP OF HVAC FUR-DOWN AT NW BR. THEN OK TO HANG DRYWALL.
---	------	--

Comments: BASEMENT EXCLUDED PRESENTLY. CALL FOR INSPECTION WHEN ALL WORK IS COMPLETED.