
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Mandrel	Steve Robbins	Passed	Wednesday, December 06, 2017

Informational

- 1 The mandrel test was done from existing MH 1-1 to 1-2 and from 1-2 to 1-3. This is an 8" line. Steve Robbins 12/06/2017 8:35 AM

Comments:
