

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20152186, Building Permit - Residential

Address: 3908 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, December 06, 2017

Corrective Action Required

1	Misc	-AS-GRADED PLOT PLAN REQUIRED. SWALE NOT PRESENT, BUT SHOWN ON PLAN -BROKEN WATER METER COVER -PROVIDE MIN. 3 FT EXTENSION FROM DOWNSPOUTS AND SUMP PUMP -INSTALL CO&SMOKE ALARM OUTSIDE FRONT BED -INSTALL AFCI BREAKER FOR THE CIRCUIT SUPPLYING MASTER BED LIGHT OUTLETS
---	------	---

Comments: