

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 1	Steve Robbins	Partial	Thursday, December 07, 2017

Informational

1 The 6" fire line up to the backflow preventer has been chlorinated and the 4 " domestic line has also been flushed and chlorinated. On Monday we will de-chlorinate and flush and begin samples on tuesday.Steve Robbins 12/01/2017 3:25 PM

Informational

2 We have de-chlorinated the lines and flushed the line. I took the first samples to the lab. 1 from the backflow preventer and one from the building with a duplicate from the building.Steve Robbins 12/07/2017 7:47 AM

**Comments:**