

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173920, Building Permit - Residential

Address: 206 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Mechanical Inspection - Residential	John Borns	Partial	Thursday, December 07, 2017

Corrective Action Required

1	Misc	CONDENSATE DRAIN LINE FROM ATTIC UNIT: PRESENTLY SECURED AT ONE PLACE AT FURNACE. SECURE AT TWO ADDITIONAL LOCATIONS.
---	------	---

**Comments: FINAL INSPECTION ON THIS PERMIT WILL BE PERFORMED AT SAME TIME THE OTHER
THREE PERMITS ARE FINAL INSPECTED.**