

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial
B&B Theatre
Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Curb - Proof Roll	Steve Robbins	Passed	Thursday, December 07, 2017

Informational

1 The proofroll for the curbs in the parking lot and private street has passed. Steve Robbins
12/07/2017 3:25 PM

DEI-Water Line - Coliform Test	Steve Robbins	Partial	Thursday, December 07, 2017
1			

Informational

1 The 6" fire line up to the backflow preventer has been chlorinated and the 4 " domestic line has also been flushed and chlorinated. On Monday we will de-chlorinate and flush and begin samples on tuesday. Steve Robbins 12/01/2017 3:25 PM

Informational

2 We have de-chlorinated the lines and flushed the line. I took the first samples to the lab. 1 from the backflow preventer and one from the building with a duplicate from the building. Steve Robbins 12/07/2017 7:47 AM

Comments: