

Christopher Hughey

From: Travis Townsley <ttownsley@prosserwilbert.com>
Sent: Thursday, December 7, 2017 4:23 PM
To: Christopher Hughey
Subject: FW: Irrigation meter size

*** This email is from an external source, use caution before clicking on links or opening attachments. ***

Chris

Here's is the message from Civil Engineer that states $\frac{3}{4}$ " meter is acceptable

Thanks,

Travis Townsley
Prosser Wilbert Construction, Inc.
13730 W. 108th Street, Lenexa, KS 66215
(P) 913-906-0104 – Ext. 103
(F) 913-906-9575
(C) 913-208-2648
ttownsley@prosserwilbert.com

From: Julie Sellers [mailto:jsellers@olssonassociates.com]
Sent: Wednesday, September 13, 2017 2:57 PM
To: Travis Townsley <ttownsley@prosserwilbert.com>
Subject: Irrigation meter size

Travis,

We can use a $\frac{3}{4}$ " meter per Lee's Summit. The irrigation plans call for 20 gpm, and the city meter capacity is 25 gpm for a $\frac{3}{4}$ " meter.

Julie Sellers, P.E. | General Civil | Olsson Associates
1301 Burlington, Suite 100 | North Kansas City, MO 64116 | jsellers@olssonassociates.com
TEL 816.587.4320 | DIR 816.299.4340 | FAX 816.587.1393



Disclaimer

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**, an innovator in

Software as a Service (SaaS) for business. Providing a **safer** and **more useful** place for your human generated data. Specializing in; Security, archiving and compliance. To find out more [Click Here](#).