

# Certificate of Occupancy

**Permit #:** PRCOM20173926  
**Address:** 205 SE GREEN ST, Unit:A, LEES SUMMIT, MO 64063  
**Inspected On:** Thursday, December 07, 2017  
**Inspected By:** John BornsMichael Weissenbach

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - John Borns Codes Commercial	Full C of O		Thursday, December 07, 2017
Occupancy Inspection - Michael Fire	Passed Weissenbach		Thursday, December 07, 2017

**Comments: OK FOR NEW OCCUPANCE CONTINGENT ON:**

- 1) TWO ELECTRICAL RECEPTACTLES FOUND TO HAVE OPEN GROUND**
- 2) SEVERAL RECEPTACLES FOUND TO BE "SOFT" OF LOOSE SIDE-TO-SIDE.**
- 3) CHECK TO ENSURE GLAZING IN DOORS IS SAFETY (TEMPERED) GLASS**

**CORRECT/RESOLVE THE ABOVE ITEMS ASAP.**