

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161761, Building Permit - Commercial

Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|---------------------------|
| Rough Framing Inspection - Commercial | John Borns | Partial | Friday, December 08, 2017 |

Partial Correction

1 Misc

OK TO COVER WHEN READY SHEAR WALLS AT:

STAIRWELLS:

SOUTH STAIR: 1ST FLOOR;

NORTH STAIR: BSMT LEVEL; 1ST FLOOR;

AT UNITS: **[BASEMENT;**

Partial Correction

2 Misc

OK TO COVER WHEN READY:

INTERIOR VERTICAL STRAPS AT GARAGE PORTALS; EXTERIOR
WALL SHEATHING FULL HEIGHT

Partial Correction

3 Misc

PRELIM FRAMING OBSERVATIONS AT: 3RD FLR; 1ST FLR;

**All Rough Inspection -
Commercial**

John Borns

Partial

Friday, December 08, 2017

Partial Correction

2 Misc

RC CHANNEL IN PLACE & OK TO COVER AT: 4TH FLOOR; 3RD
FLOOR; 2ND FLOOR COMPLETE THROUGHOUT; **[GARAGES;**

Partial Correction

3 Misc

OK TO COVER WHEN READY FRAMING & ROUGH-IN ABOVE
CEILING AND IN WALL CAVITIES: 1ST FLOOR; BASEMENT;

Comments:

