

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173801, Public Works Infrastructure Permit - Commercial

Residences at Echelon

Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Partial	Monday, December 11, 2017

Informational

- 1 Matt Munger 12/11/2017 11:54 AM
During my visit I walked along the newly installed silt fence to see that it was installed properly. I observed the fence trenched into the ground and staked. TJ had also extended the fence as an added step to ensure silt does not leave the site.

DEI-Storm - Material Verification	Matt Munger	Partial	Monday, December 11, 2017
-----------------------------------	-------------	---------	---------------------------

Informational

- 1 Matt Munger 12/11/2017 12:01 PM
While I was onsite inspecting ESC that was installed I looked over some of the existing sanitary sewer pipe that was delivered to the site. I observed 6" and 8" that was marked SDR26 with a date of September 7, 2017. I also observed sewer manholes that had the black weather proofing coating.

Comments: