

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential  
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test Tom Chandler 1		Partial	Monday, December 11, 2017
Informational 1	Tom Chandler 12/11/2017 1:29 PM Pulled samples for Day 1 testing and took to lab. Will pull day 2 samples tomorrow if day 1 pass. 5 samples and 1 duplicate taken.		
DEI-Miscellaneous PWORKS Inspection	Tom Chandler	Partial	Monday, December 11, 2017
Informational 1	Tom Chandler 12/11/2017 1:33 PM Inspected forms and compacted aggregate form ADA ramps.		

Comments: