

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161767, Building Permit - Commercial  
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, December 11, 2017

### Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT:  
SOUTH STAIRWELL:  
1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;  
2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;  
3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; **[2ND LAYER AT WELL FACE AND PRE-ROCK;**  
4TH FLOOR: **[1ST LAYER AT WELL FACE AND PRE-ROCK;**

NORTH STAIRWELL:  
1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;  
2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;  
3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; **[2ND LAYER AT WELL FACE AND PRE-ROCK;**  
4TH FLOOR: **[1ST LAYER AT WELL FACE AND PRE-ROCK;**

### Partial Correction

2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT ELEVATOR  
1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;  
2ND FLOOR: 1ST LAYER PRE-ROCK; PRE-ROCK 2ND LAYER;  
3RD FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;

### Partial Correction

3 Misc

OK TO COVER WHEN READY 5/8" TYPE X BEHIND TUBS/SHOWERS ADJACENT TO STAIRWELLS AT:  
4TH FLOOR: 1ST LAYER; **[2ND LAYER**  
3RD FLOOR: 1ST LAYER; **[2ND LAYER**

**Comments:**