

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172441, Building Permit - Residential

Address: 4721 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Khanh Nguyen	Passed	Tuesday, December 12, 2017

Suspended Slab Inspection	Khanh Nguyen	Passed	Tuesday, December 12, 2017
--------------------------------------	--------------	--------	----------------------------

Comments: