LEE'S SUMMIT

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:				
Inspection:		Inspector:	Outcome:	Date:
DEI-Site Visit		Nick Lightner	Partial	Tuesday, December 12, 2017
Informational				
1 No work going on. No ESC has been put into place. End of this week the process to water test should take place, the water main across the street on the N side needs to be covered. Nick Lightner 12/12/2017 2:16 PM				
DEI-Driveway Inspection		Nick Lightner	Passed	Tuesday, December 12, 2017
Informatio	onal			, -
1	Inspected the cross slope for the driveway approach on the N side of the property. Cross slope passed I did notice that the approach has some divets from them driving over it to pour asphalt yesterday. Nick Lightner 12/12/2017 2:22 PM			

Comments: