

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Commercial Curb Inspection	Steve Robbins	Passed	Tuesday, December 12, 2017

Informational

1 All the curbs for the parking lot and private street have been proofrolled and have all been installed with a curb machine that could be.

DEI-Sanitary Sewer - Invert	Steve Robbins	Partial	Tuesday, December 12, 2017
-----------------------------	---------------	---------	----------------------------

Corrective Action Required

1 The inverts have been poured, but when i checked the existing MH that the core drill was done on the invert does not come up to the bottom of the pipe. I called the contractor and they said they would come out and take care of it. When they take care of this we can have the camera inspection done. Steve Robbins 12/12/2017 2:23 PM

Comments: