

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20152186, Building Permit - Residential

Address: 3908 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:   | Inspector:   | Outcome: | Date:                      |
|---|--------------|----------|----------------------------|
| <b>Occupancy Inspection -<br/>Codes Residential</b> | Khanh Nguyen | Failed   | Tuesday, December 12, 2017 |

### Corrective Action Required

|   |      |   |
|---|------|---|
| 1 | Misc | -PROVIDE MIN. 3 FT EXTENSION FROM DOWNSPOUTS AND SUMP PUMP<br>-INSTALL CO&SMOKE ALARM OUTSIDE FRONT BED<br>-INSTALL AFCI BREAKER FOR THE CIRCUIT SUPPLYING MASTER BED LIGHT OUTLETS<br><br>**12/12-NO ACCESS. |
|---|------|---|

### Comments: