

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171304, Building Permit - Residential

Address: 4725 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, December 13, 2017

Corrective Action Required

1	Misc	-HAVE THE LAWN IRRIGATION GUY SUBMIT THE BACKFLOW TEST REPORT TO THE CITY -EXPOSE SEWER TRACER BOX -AC DISCONNECT: THE INNER PLASTIC COVER IS MISSING; ID THE UNGROUNDED CONDUCTORS WITH PROPER COLOR. WHITE IS FOR GROUNDED CONDUCTORS -INSTALL SPLASHBLOCKS -DEDICATE (SINGLE PLUG) THE RECEPTACLE FOR THE ALARM CONTROL BOX OR PROVIDE GFCI PROTECTION
---	------	---

Comments: