

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171979, Building Permit - Residential

Address: 204 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|------------|----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Final Mechanical Inspection - Residential | John Borns | Passed | Thursday, December 14, 2017 |

Comments: REPAIR ELECTRICAL WHIP CONNECTION AT RECESSED LIGHT FIXTURE ADJACENT TO FURNACE UNIT ABOVE CEILING. CLOSE PERMIT.