

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Invert	Steve Robbins	Passed	Thursday, December 14, 2017

Corrective Action Required

1 The inverts have been poured, but when i checked the existing MH that the core drill was done on the invert does not come up to the bottom of the pipe. I called the contractor and they said they would come out and take care of it. Steve Robbins 12/12/2017 2:23 PM

Resolved

2 The contractors have corrected the problem by bringing the invert to the bottom of the pipe. Steve Robbins 12/14/2017 2:31 PM

DEI-Street - Base Lift	Steve Robbins	Passed	Thursday, December 14, 2017
------------------------	---------------	--------	-----------------------------------

Informational

1 They are installing base this morning, it is type II base asphalt this morning. I talked with Ryan and we decided they can install at 30 degrees . Steve Robbins 12/13/2017 3:26 PM

Informational

2 The base for the parking lot and the private street has all been installed. They are planning on doing the surface on wednesday of next week if the weather is good. Steve Robbins 12/14/2017 1:46 PM

Comments:

