

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test Tom Chandler 2		Passed	Thursday, December 14, 2017

Informational

1 Tom Chandler 12/14/2017 4:01 PM Lab called to notify of test results of day 2 testing. Test results passed and emailed results to Water Utilities as well. Contractor is wanting to do the tie-ins of Monday 12/18/2017.

Comments:
