

Temporary Certificate of Occupancy

Permit #: PRRES20162861
Address: 3333 SW JESSIE CIR, LEES SUMMIT, MO 64082
Inspected On: Friday, December 15, 2017
Inspected By: Mark Harding
Expiration Date: 1/5/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Temporary C of O	Friday, December 15, 2017

Corrective Action Required:

1	Misc	-OBTAIN IRRIGATION PERMIT -REMOVE CONSTRUCTION DEBRIS FROM LOT TO WEST -CAP SEWER CLEANOUT AND BRING TO GRADE -WATER METER REQUIRED TO BE 14-18 INCHES FROM lid to lid
---	------	---