

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Friday, December 15, 2017

Partial Correction

1	Misc	-2ND FLOOR EXISTING BUILDING, 2 ROOMS APPROVED TO COVER ADJACENT TO SMOKE BARRIOR
---	------	---

Partial Correction

2	Misc	3RD FLOOR: ; DATA AND ELECTRIC ROOM APPROVED; WEST WING STAIR APPROVED. APPROVED ALL EXTERIOR WALLS. -NORTH MECHANICAL, EQUIPMENT, EAST STAIR APPROVED -SOUTH WING FROM J6 TO LINE 11, MINUS STAIR. REPAIR FIRE PROTECTION FOR STEEL COLUMN AT STAIR -RM 3-126, 3-128 TO 3-139, 141
---	------	---

Comments: