

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWLD20173826, Public Works Land Disturbance Permit

TAILOR MADE LANDING

Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Failed	Monday, December 18, 2017

Corrective Action Required

- 1 Matt Munger 12/18/2017 10:15 AM
Upon my arrival I observed silt fence in place, but there was not a construction entrance with Rip Rap put in per the plans. I spoke with Rick Mullin and he stated they wanted to put the construction entrance in where the existing driveway sits. I informed Rick if he is going to use the existing driveway, Rip Rap will need to be in place to keep mud and debris off Hamblen Rd. The streets will need to be swept clean as well from there being rocks and mud on the roadway.

Comments: