

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Street - Surface Course	Steve Robbins	Passed	Monday, December 18, 2017

Informational

1 I came by around 11:00 just to make sure the temp was at 50 for the surface, it was 51 and rising. They completed the surface on saturday.Steve Robbins 12/18/2017 9:52 AM

Comments:
