

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	Tom Chandler	Passed	Tuesday, December 19, 2017

Informational

- 1 Tom Chandler 12/19/2017 3:04 PM Air test where the wyes were repaired on the main. Tested between 50-275 and 50-278. Tested between existing MH 50-274 and 50-281.

DEI-Sanitary Sewer - Mandrel	Tom Chandler	Passed	Tuesday, December 19, 2017
------------------------------	--------------	--------	----------------------------------

Informational

- 1 Tom Chandler 12/19/2017 3:09 PM Mandreled line were sag was at between MH 50-281 and MH 50-280.

Comments: