

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161767, Building Permit - Commercial

Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, December 19, 2017

Partial Correction

1	Misc	OK TO COVER WHE READY FRAMING AND CONCEALED SYSTEMS BEHIND SHOWERS AT: [4TH FLOOR; 3RD FLOOR; PRE-ROCK AT SHOWER AREA: -1ST FLOOR-THE CLEANOUT AT THE BASE OF EACH STACK MUST BE ACCESSIBLE -THE HOLD DOWN NOT INSTALLED PROPERLY AT UNIT 5211 ALL-ROUGH AT 4TH FLOOR: -NAIL TOGETHER ALL GIRDERS -INSTALL TIE-DOWN DEVICES FOR ALL GIRDERS -CLOSE HOLES AND GAPS OF ALL DRAFTSTOPS
---	------	---

Comments: