

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171531, Building Permit - Commercial

Address: 3500 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Failed	Wednesday, December 20, 2017

Corrective Action Required

1	Misc	MC CABLES > 6' ARE REQUIRED TO BE SECURED WITHIN 12" OF JUNCTION BOXES. - INSTALL AND VENT BATH FAN. -OPEN WIRING IN HALL OUTSIDE SOUTH BATH
---	------	---

Comments: