

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mike Copeland	Partial	Thursday, December 21, 2017

Partial Correction

1 Misc

LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL.  
-ROOF TOP FIRESTOP APPROVED

Partial Correction

2 Misc

SOUTH MECHANICAL ROOM (2 HOUR): NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)

Partial Correction

3 Misc

WEST ELEVATOR SHAFT: ALL APPROVED

Partial Correction

4 Misc

SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED

Partial Correction

5 Misc

SHELL ROOMS 3169, 3170, 3163 INSIDE ROOMS APPROVED 1ST LAYER

**Comments:**