

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170618, Building Permit - Commercial

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Thursday, December 21, 2017

Corrective Action Required

1	Misc	ROCK INSPECTION-
		PARTAIL KITCHEN WALL OK TO HANG WHERE HOOD IS LOCATED.
		MEZZANINE/CATWALK-PARTAIL
		THEATERS:
		2,3,4,5,
		6-partial
		7-

Hood/Duct Inspection	Mark Harding	Partial	Thursday, December 21, 2017
-----------------------------	--------------	---------	-----------------------------

Corrective Action Required

1	Misc	HOOD LIGHT TEST ON WELDS-
		PARTIAL GROUND LIGHT INSPECTION SHOP WELDS
		-1st layer of wrap down to offset
		-2nd layer to off set

Comments: