## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRRES20173421, Building Permit - Residential
Address: 612 NW OLIVE ST, Unit:A, LEES SUMMIT, MO 6406

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Mark Harding Partial Friday, December 22, 2017

Residential

Corrective Action Required

1 Misc Stud under carport rafter at wall to floor for bearing.

ok to cover exterior.

Corrective Action Required

2

**Comments:**