

Temporary Certificate of Occupancy

Permit #: PRRES20172030
Address: 4056 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, December 27, 2017
Inspected By: Khanh Nguyen
Expiration Date: 1/26/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Wednesday, December 27, 2017

Corrective Action Required:

1	Misc	-USE GALVALNIZED NAILS FOR DECK JOIST HANGERS -REMOVE COVER FROM SMOKE ALARM IN MECHANICAL SPACE -CAP OFF OPEN WATER HEATER B-VENT
---	------	--