

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172339, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Wednesday, December 27, 2017
Alarm Test	Michael Weissenbach	Passed	Wednesday, December 27, 2017
Partial Correction 1 Misc			

**Comments: ELECTRICAL PANELS OK TO CLOSE IFF CABLE MANUFACTURER DOES NOT RECOMMEND
USE OF ANTIOXIDIZING COMPOUND AT TERMINATIONS.**